





CULTEC HVLV F-110x4 FEED CONNECTOR CHAMBER STORAGE = 1.968 CF/FT (0.1828 m3/m) ALL HVLV F-110x4 UNITS ARE MARKED WITH A COLOR STRIPE FORMED INTO THE PART ALONG THE LENGTH OF THE CHAMBER.



CULTEC, Inc.

 Subssurface Stornwater Management Systems

 P.O. Box 280
 PH: (203) 775-4416

 878 Federal Road
 PH: (800) 4-CULTEC

 Brookfield, CT 06804
 FX: (203) 775-1462

THIS DRAWING WAS PREPARED TO SUPPORT THE DESIGN ENGINEER FOR THE PROPOSED SYSTEM. IT IS THE ULTIMATE RESPONSIBILITY OF THE DESIGN ENGINEER TO ASSURE THAT THE STORMWATER SYSTEMS DESIGN IS IN FULL COMPLIANCE WITH ALL APPLICABLE LAWS AND REGULATIONS. IT IS THE DESIGN ENGINEERS RESPONSIBILITY TO ENSURE THAT THE CULTEC PRODUCTS ARE DESIGNED IN ACCORDANCE WITH CULTEC'S MINIMUM REQUIREMENTS. CULTEC INC. DOES NOT APPROVE PLANS, SIZING, OR SYSTEM DESIGNS. THE DESIGNING ENGINEER IS RESPONSIBLE FOR ALL DESIGN DECISIONS.

HVLV F110x4 FEED CONNECTOR THREE VIEW

CULTEC HVLV F110x4 FEED CONNECTOR		
PROJECT NO: -	DATE:	04/2014
DESIGNED BY: CULTEC, INC	DRAWN BY:	TECH
SCALE: N.T.S.	SHEET NO:	1 OF 1